

**FIRE SAFETY CERTIFICATE**

Certificate No.: 34/2024

Dated.: 12.09.2024

Certified that the "The PSBB Millennium School" S.No. 150/2B5/3 Periyakattupalaiyam, Cuddalore – Pudhucherry- East Cost Road, Anugraha Township, Cuddalore Taluk, Tamilnadu State Comprised of G+2 Building Occupied by "The PSBB Millennium School" have Complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Services Rules, and verified by the officers concerned of Fire Services on 12.09.2024 (date of Inspection ) in the presence of Mrs. N.Mahalakshmi, School Principal (name and Addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes Pre kg to XII<sup>th</sup> Standard (X/ XII) with effect from 16.09.2024 to 15.09.2025 for a period of year in accordance with rule and subject to compliance of specific conditions as appended:-

**CONDITIONS**

1. This License is valid for one year month from the date of issue.
  2. This No objection Certificate is issued only for approved buildings.
  3. **Four numbers of ABC 5 Kg per 200 Sq.m should be provided.**
  4. Fire Safety Systems should be maintained in good working condition.
  5. Mock drill to be conducted periodically with the help of local fire and Rescue Service Station.
  6. Any erection of permanent or temporary structure should be intimated to this department.
  7. A trained Fire Service Person, preferably retired one should be appointed.
- Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
- a) Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.
  - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
  - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
  - d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
  - e) Mock drill has to be conducted at regular intervals in consultation with the Station Officer, Fire and Rescue Services, Cuddalore.
  - f) **The class rooms should always be in the ground floor upto 3<sup>rd</sup> standards.**
  - g) The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
  - h) The classroom doors/ windows shall always open outwards.
  - i) The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
  - j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.

k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.

L) Miniature Circuit Breakers/Earth Leakage Circuit Breakers should be provided.

If here is any violation and deviation from the Govt. Rule and Act the Certificate issued will stand cancelled.

Issued on 12.09.2024 (date of issue) at Cuddalore -607001. TamilNadu State (place) by

\*Strike out whichever is not applicable.



Signature with Seal.

  
Asst. District Officer,  
Fire & Resque Services,  
Cuddalore Station.

Name

: G.Arumugam.

Designation.

: Assistant District Officer  
Fire and Rescue Station,  
Cuddalore.

To.:

The Principal,  
The PSBB Millennium School,  
S.No.150/2B5/3, Periyakattupalayam,  
Cuddalore-Pudhucherry- East Cost Road,  
Anugraha Township, Cuddalore T.K.  
TamilNadu State.

### ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to  
- NIL -

.....  
(reasons to be recorded).

(Name and designation of the authorized signatory)

\*The filled up certificate should be either in Hindi or English. If it is issued in vernacular Language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.