

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED&APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Ref: Collector, Kpm, Lr. No: RC 23640/2011/M1 Dated 19.05.2012

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakonam - 631002

Off: #4, Vanthavasi Road,  
Gandhi nagar,  
Kanchipuram - 631501

Cell: 9443106470, 9788026626

Email : dnatarajan8@gmail.com

## STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL

### STATEMENT ACCOMPANYING FORM - A

1. Name of the school and Door no of the Building : **THE PSBB MILLENNIUM SCHOOL**  
No. 9, Multi Nagar Main Road, Gerugambakkam,  
Sriperumbudur Taluk, Kancheepuram District- 602 101
2. Location (street No. Ward No Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment : S. F. Nos. 77, 78 & 79,  
No. 9, Multi Nagar Main Road, Gerugambakkam,  
Sriperumbudur Taluk,  
Kancheepuram District- 602 101
3. Year of construction : A BLOCK: GF + 3: RCC: 2009; B BLOCK: GF + 3: RCC: 2011;  
C BLOCK: GF + 3: RCC: 2011; D BLOCK: GF + 1: RCC: 2011;  
ADMIN BLOCK: GF + 3: RCC: 2011
4. Approximates cost of construction as per current rate : Rs. 290.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational
6. Purpose for which the building has hitherto been used : Educational
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under  
(i) Foundation : RCC Framed Structure  
(ii) Basement : Pile Foundation  
(iii) Superstructure : RCC Column, Plinth Beam & Brick in CM  
RCC Column & Brick in CM  
(iv) Floor & Roof are to be given : Flooring: Vitrified Tiles  
Roof: RCC Slab
8. Period for which the license is require : May be issued from 25.01.2019 to 24.01.2022  
(For Three years only)
9. Number of persons to be accommodated Refer "ANNEXURE" to this : Two Thousand Nine Hundred (2900) Pupils only

Place : Kancheepuram


Date : 28.12.2018

Signature of the Correspondent

For THE PSBB MILLENNIUM SCHOOL

S. Bhavanam

PRINCIPAL  
S. BHAVANI BASKAR

  
Signature of the Engineer  
Er. D. NATARAJAN, B.E., (CIVIL) MIE  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501  
Cell: 94431 06470, 94440 03305



Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED&APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Ref: Collector, Kpm, Lr. No: RC 23640/2011/M1 Dated 19.05.2012

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam - 631002

Off: #4, Vanthavasi Road,  
Gandhi nagar,  
Kanchipuram - 631501

Cell: 9443106470, 9788026626

Email : dnatarajan8@gmail.com

FORM - B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

THE PSBB MILLENNIUM SCHOOL, GERUGAMBAKKAM

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION OF (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING ( LICENSING ACT 1965 TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features:

1. Foundation:

- |  |                   |
|--|-------------------|
| i. Depth below ground level                          | : 12ft below G.L  |
| ii. Nature of soil met out in the foundation         | : Hard Soil       |
| iii. Pressure at foundation                          | : 12 tones / Sq.m |
| iv. Probable safe bearing capacity of the foundation | : 20 tones / Sq.m |

2. Superstructure:

- |   |   |                               |
|---|---|-------------------------------|
| i. Maximum stress in most critical Sections of masonry and concrete | a) R.C.C Concrete : 30 Kg / Sq.cm       | b) Masonry : 08 tones / Sq.m. |
| ii. Nature of masonry and concrete And its safe permissible stress  | : Brick masonry in cm: 30 tones / Sq.m. | R.C.C : 40 Kg / Sq.cm.        |

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 25.01.2019 to 24.01.2022.

Signature of the Correspondent

For THE PSBB MILLENNIUM SCHOOL

S. Bhavani

PRINCIPAL  
S. BHAVANI BASKAR

Signature of the Engineer  
Er. D. NATARAJAN, B.E., (CIVIL) M.I.E.

Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.

Cell 94431 06470, 94440 03305

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
 STRUCTURAL ENGINEER, CHARTERED ENGINEER  
 REGISTERED&APPROVED ENGINEER  
 BY THE BOARD OF ENGINEERS, TAMIL NADU.  
 PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT  
 Ref: Collector, Kpm, Lr. No: RC 23640/2011/M1 Dated 19.05.2012

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
 Palanipet, Arakkonam - 631002  
 Off: #4, Vanthavasi Road,  
 Gandhi nagar,  
 Kanchipuram - 631501  
 Cell: 9443106470, 9788026626  
 Email : dnatarajan8@gmail.com

FORM - C

**STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS  
 THE PSBB MILLENNIUM SCHOOL. GERUGAMBAKKAM**

Form of certificate of structural soundness under sub section (b) of section of 4 of the madras Public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public building (Licensing) rules 1977.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
THE PSBB MILLENNIUM SCHOOL No. 9, Multi Nagar Main Road, Gerugambakkam, Sriperumbudur Taluk, Kancheepuram District-602 101.	A BLOCK: GF+3: RCC: 09 Yrs; B BLOCK: GF+3: RCC: 07 Yrs; C BLOCK: GF+3: RCC: 07 Yrs; D BLOCK: GF+1: RCC: 07 Yrs; ADMIN BLOCK: GF+3: RCC: 07 Yrs	Rs. 290.00 Lakhs	Ground Floor +3	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational	License may be issued for the period of Three Years from 25.01.2019 to 24.01.2022.	2900 Pupils only	Building is structurally sound

Signature of the Correspondent  
 For THE PSBB MILLENNIUM SCHOOL

S. Bhavanani

PRINCIPAL  
 S. BHAVANI BASKAR

Signature of the Engineer  
 Er. D. NATARAJAN, B.E., (CIVIL)  
 Chartered Engineer  
 Panel Engineer Class 1A  
 Kanchipuram District  
 #4, Vanthavasi Road,  
 Gandhi Nagar,  
 Kanchipuram - 631 501.  
 Cell 94431 06470, 94440 03305